



401 W. Main Street  
Dillon, SC 29536

**RE: City of Dillon RFP No.: 2022  
Baseball/Softball Field Lighting**

**Uploaded via SCBO  
October 25, 2022**

---

**ADDENDUM #1 – October 25, 2022**

---

**TO: ALL RESPONSIVE HOLDERS OF THE RFP**

Acknowledge receipt of this addendum by inserting its number and date in the response to the RFP. Failure to do so may subject proposer to disqualification. This addendum forms a part of the response to the RFP. It modifies it as follows:

**CLARIFICATIONS**

1. The LED lighting system shall be capable of providing 50 foot-candle (fc) for the infield areas and 30fc for the outfield areas.
2. Pole locations at all fields need to be determined for 200' fields.
3. The total number of poles with the cost shall be stated in the proposer's response. A reduction in the number of poles by using common pole locations will be considered and the cost savings shall also be stated in the response.
4. Spill/Glare light control technology is mentioned for this project, however, it will not be required for the proposer to show the fc values at specific distances from the fields.
5. The existing wood poles and lights removed shall be stockpiled onsite and retained by the City.

**END OF ADDENDUM**